

ADDENDUM NO. 1

June 15, 2020

TO THE PLANS AND PROJECT MANUAL FOR

Wasatch Elementary Re-Roof

Prepared by:



233 South Pleasant Grove Blvd. Suite 105
Pleasant Grove, Utah 84062
(801) 769-3000 Office
(801) 769-3001 Fax



This addendum is hereby made a part of the contract documents. It shall be the responsibility of each Contractor to notify his subcontractors of the contents of this addendum. In case of conflict between drawings, specifications and the Addendum, this Addendum shall govern. All changes, corrections, deletions and/or additions to the initial bidding documents shall be included in the bid.

ADDENDUM NO. 1

June 15, 2020

Architectural Items

1. **Sign in Sheet:** See the attached sign-in sheet of approved bidders for this project.
2. **Sheets A130 – A134:** General Note E should read: *“INSULATE ENTIRE ROOF, MATCH EXISTING INSULATION THICKNESS OF 1.5" POLYISOCYANURATE ABOVE ROOF DECKING.”*

END OF ADDENDUM

